



SL-17FR TEST RESULTS

| Door Assembly |
|---|
| 60 min pp category A door |
| 90 min pp category B door |
| 90 min pp category A door |
| Temperature rise @ 30 min, 250 °F when vision lites do not exceed 100 in ² |
| Temperature rise @ 60 min, 450 °F max |