



## SL-20FR TEST RESULTS

Door Assembly
60 min pp category A door
90 min pp category B door
90 min pp category A door
Temperature rise @ 30 min, 250 °F when vision lites do not exceed 100 in <sup>2</sup>
Temperature rise @ 60 min, 450 °F max